

FUELSTAT®

The test for microbial contamination in jet and diesel fuels

From **sample to report** in less than 15 minutes with **FUELSTAT® Result**

FUELSTAT® ANALYSIS REPORT																						
Company name: Standard Address inputted From Portal Registered User: Engineers Name Address: Input from Portal Registered Address Test date: 24-JAN-2019 Post code: From Portal GPS location: Country: United Kingdom Fuelstat result number: 3,361 Customer reference: 124 - Portal Template Printout date: 24-JAN-2019																						
Identity: Example Test Asset: Jet 1 Tank: Wing Fuel lot: 4 Fuelstat test lot: HR 2 411	Bacteria: Negligible Fungi: Heavy Hormoconis resinae: Negligible Overall result: Heavy Test method: ASTM D8070-16																					
Comments Example test Report - Annual Maintenance Check																						
FUELSTAT® Result data interpretation and guidance <table border="1"> <thead> <tr> <th>Alert level</th> <th>Phase</th> <th>Target antigen limits</th> </tr> </thead> <tbody> <tr> <td>Negligible</td> <td>Fuel Water</td> <td>Up to 150 µg/L Up to 33 µg/ml</td> </tr> <tr> <td colspan="3">Negligible — Maintain good housekeeping practices.</td> </tr> <tr> <td>Moderate</td> <td>Fuel Water</td> <td>Between 150-750 µg/L Between 33-166 µg/ml</td> </tr> <tr> <td colspan="3">Moderate — Repeat the test to confirm the result and increase the frequency of water drainage.</td> </tr> <tr> <td>Heavy</td> <td>Fuel Water</td> <td>Greater than 750 µg/L Greater than 166 µg/ml</td> </tr> <tr> <td colspan="3">Heavy — Seek further advice if required, such as increased water drainage and/or biocide treatment.</td> </tr> </tbody> </table>		Alert level	Phase	Target antigen limits	Negligible	Fuel Water	Up to 150 µg/L Up to 33 µg/ml	Negligible — Maintain good housekeeping practices.			Moderate	Fuel Water	Between 150-750 µg/L Between 33-166 µg/ml	Moderate — Repeat the test to confirm the result and increase the frequency of water drainage.			Heavy	Fuel Water	Greater than 750 µg/L Greater than 166 µg/ml	Heavy — Seek further advice if required, such as increased water drainage and/or biocide treatment.		
Alert level	Phase	Target antigen limits																				
Negligible	Fuel Water	Up to 150 µg/L Up to 33 µg/ml																				
Negligible — Maintain good housekeeping practices.																						
Moderate	Fuel Water	Between 150-750 µg/L Between 33-166 µg/ml																				
Moderate — Repeat the test to confirm the result and increase the frequency of water drainage.																						
Heavy	Fuel Water	Greater than 750 µg/L Greater than 166 µg/ml																				
Heavy — Seek further advice if required, such as increased water drainage and/or biocide treatment.																						

Portal version: 1.2.2



FUELSTAT®

- **Lowest** cost to result of any test on the market
- The **ONLY** true on-site test that gives dependable results even in the dirtiest of conditions

FUELSTAT®

FUELSTAT® Plus

- Ultra simple test that requires **4 drops** of sample
- **15 minutes** to result as opposed to 4-7 days!



Dependable Results Even in the Dirtiest Conditions

FUELSTAT®

- Unique immunoassay technology
- Detects only specific microorganisms

FUELSTAT®


- Carried out on site, so complying with ASTM D6469 - testing for contamination within 24 hours
- Avoids time delays and expense associated with sample transportation to laboratory



Microbial Contamination causes massive unplanned costs and disruption

- Catastrophic effects such as blocked fuel systems, damaged fuel probes and corroded tanks
- Repair and replacement costs can be \$millions if left to develop
- Disruption to use of assets can cause substantial operational problems






Data Management: Real Time Reporting Easy to download app

- Available on IOS and Android Smartphones
- Instant verification of result and transfer of data

FUELSTAT® Report.

- Excel format
- All microbial testing data on one spreadsheet



Results straight into Excel

FUELSTAT® ANALYSIS REPORT																															
Company name: Standard Address inputted From Portal Address: Input from Portal Post code: From Portal Country: United Kingdom Customer reference: 124 - Portal Template																															
Registered User: Engineers Name Test date: 24-JAN-2019 GPS location: Fuelstat result number: 3,361 Printout date: 24-JAN-2019																															
Identity: Example Test Asset: Jet 1 Tank: Wing Fuel lot: 4 Fuelstat test lot: HR 2 411	Bacteria: Negligible Fungi: Heavy Hormoconis resinae: Negligible Overall result: Heavy Test method: ASTM D8070-16																														
Comments Example test Report - Annual Maintenance Check																															
FUELSTAT® Result data interpretation and guidance <table border="1"> <thead> <tr> <th>Alert level</th> <th>Phase</th> <th>Target antigen limits</th> </tr> </thead> <tbody> <tr> <td>Negligible</td> <td>Fuel</td> <td>Up to 150 µg/L</td> </tr> <tr> <td></td> <td>Water</td> <td>Up to 33 µg/ml</td> </tr> <tr> <td colspan="3">Negligible — Maintain good housekeeping practices.</td> </tr> <tr> <td>Moderate</td> <td>Fuel</td> <td>Between 150-750 µg/L</td> </tr> <tr> <td></td> <td>Water</td> <td>Between 33-166 µg/ml</td> </tr> <tr> <td colspan="3">Moderate — Repeat the test to confirm the result and increase the frequency of water drainage.</td> </tr> <tr> <td>Heavy</td> <td>Fuel</td> <td>Greater than 750 µg/L</td> </tr> <tr> <td></td> <td>Water</td> <td>Greater than 166 µg/ml</td> </tr> <tr> <td colspan="3">Heavy — Consider remedial treatment, such as increased water drainage and/or biocide treatment. Seek further advice if required.</td> </tr> </tbody> </table>		Alert level	Phase	Target antigen limits	Negligible	Fuel	Up to 150 µg/L		Water	Up to 33 µg/ml	Negligible — Maintain good housekeeping practices.			Moderate	Fuel	Between 150-750 µg/L		Water	Between 33-166 µg/ml	Moderate — Repeat the test to confirm the result and increase the frequency of water drainage.			Heavy	Fuel	Greater than 750 µg/L		Water	Greater than 166 µg/ml	Heavy — Consider remedial treatment, such as increased water drainage and/or biocide treatment. Seek further advice if required.		
Alert level	Phase	Target antigen limits																													
Negligible	Fuel	Up to 150 µg/L																													
	Water	Up to 33 µg/ml																													
Negligible — Maintain good housekeeping practices.																															
Moderate	Fuel	Between 150-750 µg/L																													
	Water	Between 33-166 µg/ml																													
Moderate — Repeat the test to confirm the result and increase the frequency of water drainage.																															
Heavy	Fuel	Greater than 750 µg/L																													
	Water	Greater than 166 µg/ml																													
Heavy — Consider remedial treatment, such as increased water drainage and/or biocide treatment. Seek further advice if required.																															
Phone make: Apple Phone model: iPhone 6s App version:	Portal version: 1.2.2 Analysis approved by:																														
<small> Disclaimer — FUELSTAT® Result is designed for use with tests which are fully compliant with ASTM D8070-16. However, readings obtained using FUELSTAT® Result are currently outside the scope of ASTM D8070-16. Operators should visually validate test results as per ASTM D8070-16. The accuracy of this report may be dependent on the accuracy of the sample provided. Full terms of use available on the Conidia Bioscience Ltd. website www.conidia.com. For Any Technical Assistance Telephone: +44 (0)1491 829102 Conidia Bioscience Limited: 3 Acorn Business Centre, Northarbour Road, Cosham, Portsmouth, PO6 3TG, United Kingdom. Registration number: 03965471 VAT number: 760 2156 55 www.conidia.com </small>																															

Analysis Report.

- Fully detailed report can be instantly produced in PDF format



The FUELSTAT® Solution

As simple as 1-2-3

Test. Result. Report.



FUELSTAT® Plus Test


1

- Accurate results anywhere, carried out by anyone, and learned in minutes
- Immediate decisions can be made without delay
- Results within 15 minutes

FUELSTAT® Result

2

- Reduces risk of misinterpretation
- Immediate visual verification of result
- No need for additional equipment other than a smartphone



FUELSTAT® ANALYSIS REPORT	
Company name: Standard Address inputted From Portal Registered User: Engineers Name	
Address: Input from Portal Registered Address	Test date: 24-JAN-2019
Post code: From Portal	GPS location:
Country: United Kingdom	Fuelstat result number: 3,361
Customer reference: 124 - Portal Template	Printout date: 24-JAN-2019
Identity: Example Test	Bacteria: Negligible
Asset: Jet 1	Fungi: Heavy
Tank: Wing	Hormoconis resinae: Negligible
Fuel lot: 4	Overall result: Heavy
Fuelstat test lot: HR 2 411	Test method: ASTM D8070-16
Comments	
Example test Report - Annual Maintenance Check	
FUELSTAT® Result data interpretation and guidance	
Alert level	Phase
Negligible	Fuel
	Water
	Target antigen limits
	Up to 150 µg/L
	Up to 33 µg/ml
Moderate	Fuel
	Water
	Between 150-750 µg/L
	Between 33-166 µg/ml
Heavy	Fuel
	Water
	Greater than 750 µg/L
	Greater than 166 µg/ml
Phone make: Apple	
Portal version: 1.2.2	
Phone model: iPhone 6s	
Analysis approved by:	
App version:	
Disclaimer — FUELSTAT® Result is designed for use with tests which are fully compliant with ASTM D8070-16. However, readings obtained using FUELSTAT® Result are currently outside the scope of ASTM D8070-16. Operators should visually validate test results as per ASTM D8070-16. The accuracy of this report may be dependent on the accuracy of the sample provided. Full terms of use available on the Conidia Bioscience Ltd. website www.conidia.com. For Any Technical Assistance Telephone: +44 (0)1491 829102	
Conidia Bioscience Limited: 3 Acorn Business Centre, Northharbour Road, Cosham, Portsmouth, PO6 3TG, United Kingdom. Registration number: 03965471 VAT number: 760 2156 55 www.conidia.com	

FUELSTAT® Report

3

- Traceability of testing
- Identification of hotspots for planning
- Proof of test, proof of result, proof of method

Organisation	Capture date	Engineer	Identity	Asset	Tank No	Test Lot #	Result
ACME plc	17/04/2017	eng10@acme.com	Test equ	ABC123	Left	1204	98765
ACME plc	17/05/2017	eng11@acme.com	Test equ	ABC123	Middle	1205	98765
ACME plc	17/06/2017	eng007@acme.com	Test equ	ABC123	Right	1206	98765

Tried and trusted globally. Unique innovative solution leads to huge growth of **FUELSTAT®**

FUELSTAT® PROTECTS

tests sold 120,000 per annum	over 130 countries globally	more than 400 airlines	more than 10 major oil companies
---	---	-------------------------------------	--

FUELSTAT® SAVES

cost reduction, less
effort, less time

50%
savings

labour hours saved

+ 1,0000000

**FUELSTAT® has OEM listings from
Airbus, Boeing, Bombardier, Embraer, Fokker amongst others...**



FUELSTAT® meets the ASTM International
D8070-16 Standard



FUELSTAT® is listed as an approved
product by Joint Inspection Group



Strategic
Partner

FUELSTAT® is listed as an approved
product by IATA. Conidia Bioscience is a
Strategic Partner with IATA.

FUELSTAT®

Who we are:

FUELSTAT® fuel tests are developed, manufactured and marketed by Conidia Bioscience Limited. Based in UK, Conidia Bioscience Limited was founded in early 2000's by experts in immunoassay techniques and holds the internationally patented intellectual property for FUELSTAT®.

Where to find us:

FUELSTAT is distributed globally by a network of specialist distributors covering the major sectors. Contact info@conidia.com who will arrange for a distributor to support you.



T: +44 (0)1491 829 102 | **E:** info@conidia.com | **W:** www.conidia.com

FUELSTAT®, FUELSTAT® Plus and FUELSTAT® Result are registered trademarks of
Conidia Bioscience Ltd, Bakeham Lane, Egham, Surrey, TW20 9TY